



Product Service

# Attestation of Conformity

No. N8A 105544 0011 Rev. 00

**Holder of Certificate:** Ningbo Defa Electronic Technology Co., Ltd.

No.185 Beier Road, Xinyuan Village, Xiaolin Town  
315321 Cixi City, Ningbo  
PEOPLE'S REPUBLIC OF CHINA

**Product:** Terminal block

**Model(s):** DF-2604-x

“x” stands for number of clamping units,  
can be 1 to 24, in step of 1.

DF-21y

“y” stands for number of clamping units,  
can be 2 to 8, in step of 1.

**Parameters:**

Rated connecting capacity: 0,2mm<sup>2</sup> to 1,5mm<sup>2</sup> (for DF-2604-1)  
0,2mm<sup>2</sup> to 4,0mm<sup>2</sup> (except the DF-2604-1)

Maximum ambient  
temperature:

T120

Degree of protection:

IP00

Number of terminals:

Single terminal device

Kind of conductor:

Flexible, Rigid (solid or stranded)

Type of terminal:

Screwless-type terminals

**Tested  
according to:**

EN 60998-1:2004  
EN 60998-2-2:2004

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 874102208814-00

**Date,** 2022-09-29

( Jie Zhu )

Page 1 of 1

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.